

**Nemko Ltd**  
15 Chelsea Fields Estate,  
Western Road,  
London, SW19 2QA, UK

T: +44 (0)20 8646 8383  
F: +44 (0)20 8646 8099  
E: [marketing@nemko.co.uk](mailto:marketing@nemko.co.uk)

[www.nemko.co.uk](http://www.nemko.co.uk)

# TEST CERTIFICATE

**No: C03/33389**

Client

**Ambi-Rad Limited**  
**Fens Pool Avenue**  
**Brierley Hill, West Midlands**  
**DY5 1QA, United Kingdom**

Client Contact

**Ian Vaughan**

Item

**Air Curtains / Fan heaters, fixed - at high level**

Models: AC100SE AC100HE  
AC150SE AC150HE  
AC200SE AC200HE

Specification(s) to which  
above unit/s have been tested

**BS EN 60335-2-30:1997**  
and deemed to comply

Date sample(s) received

**27 June 2003**

Test period

**9 July 2003 to 31 July 2003**

Date of Issue

**12 August 2003**

***Compliance with a Harmonised European  
Standard also gives the presumption of  
compliance with the Principal Elements of the  
Safety Objectives of the Low Voltage Directive  
73/23/EEC***

Signed



**Marc Tinsel**  
**(Certifying Officer)**

Relating to Test Report File(s) **33389**  
held at Nemko Ltd

To be read in conjunction with page 2 attached



0225  
Form No: QF102  
Issue No. 3  
Issue Date: 08.08.01



**Nemko Ltd**

15 Chelsea Fields Estate,  
Western Road,  
London, SW19 2QA, UK

T: +44 (0)20 8646 8383  
F: +44 (0)20 8646 8099  
E: [marketing@nemko.co.uk](mailto:marketing@nemko.co.uk)

[www.nemko.co.uk](http://www.nemko.co.uk)

**Certificate No:** C03/33389

**Client:** Ambi-Rad Ltd

THIS CERTIFICATE APPLIES ONLY TO THE PARTICULAR SAMPLE UNIT(S) TESTED AND TO THE SPECIFIC TESTS CARRIED OUT AS DETAILED IN THE REPORT FILE HELD AT NEMKO LTD.

THIS TEST CERTIFICATE DOES NOT COVER ELECTROMAGNETIC COMPATIBILITY

IT SHOULD BE NOTED THAT ONLY A LIMITED NUMBER OF UNITS HAVE BEEN TESTED. IT IS THEREFORE ESSENTIAL FOR THE MANUFACTURER OR SUPPLIER OF THIS PRODUCT TO ENSURE THAT THE QUALITY OF ALL PRODUCTION UNITS IS OF THE SAME STANDARD AS THAT OF THE SAMPLE(S) CHECKED

WHERE FULL TESTING OF APPROVED COMPONENTS HAS NOT BEEN CARRIED OUT AS PART OF THIS REPORT, IT IS THE RESPONSIBILITY OF THE MANUFACTURER OR SUPPLIER TO ENSURE THE COMPONENTS USED IN PRODUCTION UNITS ARE AS THAT OF THE RELATED CERTIFICATES AND SUPPORTING DOCUMENTATION.

**Condition of test sample:-**

**Notes relating to this certificate:-**

Good

**Serial No:-** --

Ratings of models covered:

AC100SE 9kW

AC100HE 12kW

AC150SE 12kW

AC150HE 18kW

AC200SE 18kW

AC200HE 24kW

All models: 400-415V 3N AC Class I IPX0  
permanent connection to fixed wiring

**Summary of files listed on page 1:-**

33389

Full Test

\*\*\*\*\*END OF CERTIFICATE\*\*\*\*\*

## EC Declaration of Conformity

Name and address  
of manufacturer:

Ambirad Ltd  
Fens Pool Ave  
Brierley Hill  
Dudley  
West Midlands  
DY5 1QA

Name of Device:


AC Air Curtain Series

I, the undersigned, hereby declare that the product range specified above conforms with the essential safety requirements of the Low Voltage Directive 2006/95/EEC and the EMC Directive 2004/108/EEC.

Date:

16 Nov 2009.

Signature:



G Turner  
New Product Development Manager