

We inform that the ventilation grille production P.P.H.U. SAW-POL
to the system of raised floor type

KPP-1 600x600

It has been tested endurance using static load
according to PN-EN 12825:2002/Ap1:2005
and was qualified to the appropriate classes:

- load class according to PN-EN 12825 - **2**
- class deflection according to PN-EN 12825- **C**

Classification documented report from studies:
NR LK00-01823/13/Z00NK from day 20 august 2013r.